



28' HMA PAVEMENT SECTION
TYPICAL CROSS SECTION

NTS

REV: 8/14/18

NOTES:

1. LIME SHALL BE APPLIED AT 6% BY WEIGHT MINIMUM QUANTITY IS 63LBS./SY. IN SOME AREAS A GREATER QUANTITY (OR A LIME SERIES TEST) MAY BE REQUIRED AT THE CITY'S DISCRETION.
2. FOR PI LESS THAN 15, LIME MAY BE OMITTED WITH PRIOR APPROVAL FROM THE CITY.
3. CEMENT SHALL BE APPLIED AT 5% BY WEIGHT. MINIMUM QUANTITY IS 45LBS./SY.
4. FOR 30" GUTTER DETAIL, SEE "SEPARATE CURB & GUTTER" DETAIL.
5. CUL DE SAC SHALL HAVE A 7 INCH PARABOLIC CROWN.



CITY OF ARLINGTON, TEXAS

28' HMA PAVEMENT SECTION

DATE:	SCALE: NTS	SHEET _____ OF _____
DESIGNED BY:	DRAWN BY:	CHECKED BY: