



### 38' HMA PAVEMENT SECTION TYPICAL CROSS SECTION

NTS

REV: 8/14/18

**NOTES:**

1. LIME SHALL BE APPLIED AT 6% BY WEIGHT MINIMUM QUANTITY IS 63LBS./SY. IN SOME AREAS A GREATER QUANTITY (OR A LIME SERIES TEST) MAY BE REQUIRED AT THE CITY'S DISCRETION.
2. FOR PI LESS THAN 15, LIME MAY BE OMITTED WITH PRIOR APPROVAL FROM THE CITY.
3. CEMENT SHALL BE APPLIED AT 5% BY WEIGHT. MINIMUM QUANTITY IS 45LBS./SY.
4. FOR 30" CURB & GUTTER, SEE "SEPARATE CURB & GUTTER" DETAIL.



CITY OF ARLINGTON, TEXAS

### 38' HMA PAVEMENT SECTION

DATE:	SCALE: NTS	SHEET ____ OF ____
DESIGNED BY:	DRAWN BY:	CHECKED BY: