


NOTES:

1. ELEVATION OF THE FOUNDATION TOP SHALL BE THE SAME AS THE ELEVATION OF THE SIDEWALK, IF ANY, AT THE FOUNDATION OR THE CROWN OF THE ROADWAY UNDER THE DAVIT ARM, WHICHEVER IS HIGHER. THE CONTRACTOR SHALL VERIFY THE ELEVATIONS.
2. EACH FOUNDATION SHALL HAVE AT LEAST TWO 2" (MIN) CONDUITS EACH ORIENTED AS NEEDED TO SERVE THE ENTERING CABLES.

FOUNDATION

NTS

REV: 6/6/18

 CITY OF ARLINGTON, TEXAS		
FOUNDATION		
DATE:	SCALE: NTS	SHEET ___ OF ___
DESIGNED BY:	DRAWN BY:	CHECKED BY: