



**NOTES:**

1. IF SIDEWALK IS NOT PROPOSED, EXTEND FLUME AND TRANSITION TO TOP OF STREET CURB.
2. CONCRETE SHALL BE CLASS C, 5 1/2 SACK, 3600 PSI.

OVERFLOW FLUME  
(TRANSITION TO SIDEWALK)  
PROFILE

NTS

REV: 7/25/17

<b>CITY OF ARLINGTON, TEXAS</b>		
<b>OVERFLOW FLUME (TRANSITION TO SIDEWALK) PROFILE</b>		
<b>DATE:</b>	<b>SCALE:</b> NTS	<b>SHEET:</b> OF
<b>DESIGNED BY:</b>	<b>DRAWN BY:</b>	<b>CHECKED BY:</b>