



THE PIPE SHALL BE BEDDED IN A MINIMUM OF SIX INCHES (6") OF CRUSHED STONE EXCEPT IN ROCK OR IN WET OR UNSTABLE TRENCHES WHERE AN ADDITIONAL 3 INCHES OF CRUSHED STONE WILL BE ADDED TO THE STANDARD BEDDING REQUIREMENTS. CRUSHED STONE SHALL MEET C.O.G. 504.2.2.1 CRUSHED STONE EMBEDMENT - AGGREGATE GRADE 4. RIVER ROCK/GRAVEL WILL BE ALLOWED AS LONG AS IT MEETS THIS GRADATION.

AFTER THE PIPE HAS BEEN LAID AND THE JOINTS MADE, CRUSHED STONE SHALL BE PLACED FROM THE BOTTOM OF THE PIPE TO THE TOP OF THE PIPE. THE MATERIAL SHALL BE PLACED UNIFORMLY ON BOTH SIDES OF THE PIPE IN ORDER TO PREVENT DISTURBANCE OF THE PIPE AND, IF NECESSARY, BLOCKING SHALL BE PLACED AGAINST THE SIDES OF THE TRENCH TO PREVENT DISPLACEMENT OF THE PIPE. FILTER FABRIC SHALL BE PLACED OVER THE FULL WIDTH OF THE EMBEDMENT PRIOR TO TRENCH BACKFILL OPERATIONS. PIPE EMBEDMENT FILTER FABRIC MATERIALS AND CONSTRUCTION METHODS SHALL CONFORM TO CITY OF ARLINGTON STANDARDS AND SPECIFICATIONS.

RCP STORM PIPE EMBEDMENT  
NTS

REV: 7/6/17



CITY OF ARLINGTON, TEXAS

RCP STORM PIPE EMBEDMENT

DATE:	SCALE: NTS	SHEET _____ OF _____
DESIGNED BY:	DRAWN BY:	CHECKED BY: