



CURB & GUTTER SIZE	"L" REBAR DIMENSION
18"	7 1/2" X 12"
24"	7 1/2" X 18"
30"	7 1/2" X 24"

**SEPARATE CONCRETE  
CURB & GUTTER**

NTS REV: 7/17/17

**NOTES:**

1. REINFORCEMENT SHALL BE NO. 4 REBAR.
2. CONCRETE SHALL BE CLASS C, 5 1/2 SACK, 3600 PSI.
3. TOOLED JOINTS SHALL BE PLACED AT FIVE FOOT INTERVALS OR MATCHING ABUTTING SIDEWALK JOINTS AND DRIVEWAY JOINTS.
4. EXPANSION JOINTS SHALL BE PLACED AT ALL INTERSECTIONS, PCs, PTs DRIVEWAYS, INLETS, OTHER CURB AND GUTTER OR EVERY 200 FEET.
5. REMOVE AN ADDITIONAL 8 INCHES THICK OF EXISTING MATERIAL UNDER NEW CURB AND GUTTER LIMITS, ONE FOOT BACK OF CURB, AND REPLACE WITH 8 INCHES CTB COMPACTED TO 95% DENSITY PER TEX-113E AT OPTIMUM TO PLUS 4%.
6. SEPARATE CURB AND GUTTER SHALL BE PLACED ON 8 INCH CEMENT TREATED BASE (CTB). CTB IS SUBSIDIARY TO CURB AND GUTTER UNIT PRICE.



CITY OF ARLINGTON, TEXAS

**SEPARATE CONCRETE  
CURB & GUTTER**

DATE:	SCALE: NTS	SHEET ____ OF ____
DESIGNED BY:	DRAWN BY:	CHECKED BY: