


NOTES:

1. FUSING SHALL BE IN-LINE CARTRIDGE TYPE RATED 10 AMPS AT 600 VOLTS SIMILAR TO THE MCGRAW EDISON CO. TRON WATERPROOF FUSEHOLDER.
2. FUSE CARTRIDGE SHALL BE LOCATED NEAR THE POINT OF CONNECTION TO THE SECONDARY POWER SOURCE AND INSTALLED IN SUCH A MANNER THAT THE FUSE CAN BE MAINTAINED SAFELY.
3. ALL BARE CONNECTIONS AND CONDUCTORS SHALL BE TAPED FOR AN INSULATION VALUE OF 600 VOLTS MINIMUM.
4. SOURCE-SIDE CONDUCTORS SHALL BE A MINIMUM NO. 6 SOLID COPPER OR EQUIVALENT STRENGTH ALUMINUM CONDUCTOR IN ORDER TO SUPPORT THE WEIGHT OF FUSEHOLDER

SPECIFICATION FOR FUSING
STREET LIGHT TAPS

NTS

REV: 6/18/18

 CITY OF ARLINGTON, TEXAS		
SPECIFICATION FOR FUSING STREET LIGHT TAPS		
DATE:	SCALE: NTS	SHEET ____ OF ____
DESIGNED BY:	DRAWN BY:	CHECKED BY: